



Installation Instructions



- 1** Determine the proper length of flexible duct for diffuser connection. (Be sure to include enough duct to allow the FlexFlow Elbow to form a smooth 90° turn.)



- 2** Connect flexible duct to diffuser using manufacturer's standard installation instructions. (The FlexFlow Elbow is not designed to replace the nylon or metal clamp used to secure the flexible duct inner core.)



- 3** Position the FlexFlow Elbow under the flexible duct with the throat facing toward the branch tap.



- 4** Secure the FlexFlow Elbow to the diffuser collar by sliding the male end of the strap through the female connector. Pull the strap tight.



- 5** Fasten the second strap by sliding the male end through the female connector. (Do not over-tighten and compress the insulation or inner core.)



- 6** Cut off excess on both straps. (As an option for added connection security, you may install screws through the FlexFlow Elbow strap into the diffuser collar.)